

Keystone Solar Future Project

PPL Electric Utilities Corporation

Modeling Inverter Capabilities in DERMS

Objectives

The Keystone Project is an innovative program to develop and evaluate a technology platform to manage and monitor DER, and improve the interconnection process.



Interconnection Web Portal

*Eligible residential
customers
approval in less
than 24 hours*



DERMS


*Central platform with
Distributed Energy
Resource-aware
algorithms for
monitoring and*



Proof of Scalability

*DERMS Pilot
technology demonstration
high penetration
simulation*

DER Modeling Reference



Example:

1 Solar Site → 5 Inverters →
Vol/VAR Curve 1 Enabled on
1 Inverter

DER Modeling



Analyst Attributes - DMSENERGYRES

Identifiers	
Name	DER_SP_XFR386186
ID	DER_SP_XFR386186
Address	
Service Center	
Permission Area	QUARVILL
Normal Station and Feeder	QVIL 65604
Normally De-energized	False
Advanced Applications Eligibility Override	True
Constructed Phase(s)	C
Future Phase(s)	
Node	N_XFR386186_L
Regulation Node	N_XFR386186_L
Ownership	Unknown
Device Type	Solar
Connectivity Data (Real Time)	
Station and Feeder	QVIL 65604
Status	Connected
Last Disconnection Time	--
Last Disconnect Reason	Low Voltage Out of Range
Inverter ID	INV_SP_XFR386186

DER System Output

Engineering Data		
Nominal Voltage	0.21 kV LL / 0.12 kV LG	
Energy Resource Model Name	ER10	
kVA size	10.00	
Voltage Schedule Name	--	
Real Power Schedule Name	PVPOWER_10	
Reactive Power Schedule Name	PQReactivePower	
Slack Bus	False	
Type	PQ	
Primary Source	False	
Wye Connected	True	
Grounded	True	
Contributes To Fault Current	True	
Voltage Target (%)	--	
Voltage Regulation is Line to Line	False	
Control Capability		
Excitation Mode	Constant Voltage	
Connection Type	Induction	
Real Power Target (kW)	1.00	
Reactive Power Target (kVAR)	2.00	
Phase(s) Measured	C	
High Disconnect Voltage Limit	126.00 kV	
Low Disconnect Voltage Limit	114.00 kV	
LVM Control Type	VAR Control	
Maximum Voltage Before Separation From the Network (Per unit)	1.050000	
Minimum Voltage Before Separation From the Network (Per unit)	0.950000	
Maximum Frequency Before Separation From the Network (Hz)	63.000000	
Minimum Frequency Before Separation From the Network (Hz)	56.000000	
	Maximum	Minimum
Real Power Output (kW)	10.00	1.00
Reactive Power Output (kVAR)	6.00	-5.00

DER Modeling



Analyst Output - DMSENERGYRES

- □ ×

Identifiers				
Name	DER_SP_XFR386412			
ID	DER_SP_XFR386412			
Address				
Constructed Phase(s)	C			
Network Application Results				
Distribution Power Flow (DPF) Solution Time	05/11/2019 02:40:00 AM			
Distribution Power Flow (DPF) Solution Status	Solved / BLA Converged			
	Phase A	Phase B	Phase C	ABC
Total Real Power (kW)	--	--	-0.00	-0.00
Total Reactive Power (kVAR)	--	--	1.99	1.99
Total Apparent Power (kVA)	--	--	1.99	1.99
Voltage (LL)	--	--	--	--
Voltage (LG)	--	--	116.02 V 87.53 Deg LG	
Current (Amps)	--	--	17.50 Amp -3.50 Deg	
Engineering Data				
Nominal Voltage	0.207846 kV LL / 0.120000 kV LG			
	Maximum	Minimum		
Real Power Output (kW)	10.00	1.00		
Reactive Power Output (kVAR)	6.00	-5.00		

DER System Output




DER Limits




Inverter Modeling

- Geographic/Static Modeling
 - Nameplate
 - Lat/Lon
 - Manufacturer
- Capability Modeling
- Setting Modeling
- SCADA/DERMS Modeling



Inverter Modeling – Attributes/DERMS



Connectivity Data (Real Time)	
Station and Feeder	QVIL 65604
Status	Disconnected
Last Disconnection Time	04/05/2019 11:04:58 AM
Last Disconnect Reason	Low Voltage Out of Range
Inverter ID	INV_SP_XFR386985
Engineering Data	
Nominal Voltage	0.21 kV LL / 0.12 kV LG
Energy Resource Model Name	ER5
kVA size	5.00
Voltage Schedule Name	-
Real Power Schedule Name	PVPOWER_5
Reactive Power Schedule Name	PQReactivePower
Slack Bus	False
Type	PQ



Inverter Status



Connectivity History



Inverter Power Schedule



Inverter Control Type

Inverter Modeling – SCADA/DERMS

Current Output

ANALOG		
AMPA	XXXXXX	
AMPB	XXXXXX	
AMPC	XXXXXX	
VAN	XXXXXX	
VBN	XXXXXX	
VCN	XXXXXX	
W	XXXXXX	
HZ	XXXXXX	
VA	XXXXXX	
VAR	XXXXXX	
PF	XXXXXX	
PRTG	XXXXXX	
QRT1	XXXXXX	
QRT4	XXXXXX	
ACNT	XXXXXX	
WMAX	XXXXXX	
PFSET	XXXXXX	
QMAX	XXXXXX	

AC Voltages

Watt Output

Inverter Freq

VA Output

VAR Output

Power factor

Inverter Rating

Max W Output

Max VAR Output

Set control mode

Set connection status

Set power factor

Set kVAR

SETPOINT		
SACM		XXXXXX
SCS		XXXXXX
SPF		XXXXXX
SQ		XXXXXX

Challenges

- Register Mapping is not standardized across inverters
- IEEE 1547-2018 capabilities are not fully reflected
- Practical Challenges of implementing the settings

Questions?

